

OPERATING INSTRUCTIONS

MODEL CKV-05 THD

IN-LINE ADJUSTABLE CHECK VALVE



APPLICATIONS:

Valve should only be used for non-corrosive fluids, or where the materials selected are compatible with the fluid and will not cause corrosive buildup which could keep the poppet from opening. (Consult Factory) When liquid contain debris or other solid matter, a strainer with fine wire mesh should be placed before the check valve. Strainers can be purchased from STRA-VAL to address this concern.

PRINCIPLE OF OPERATION

This is a poppet (piston) and spring type check valve where the spring constantly opposes the pressure acting against the piston seat area. The desired cracking pressure is achieved by compressing the spring until the spring force is adequate to balance the pressure force acting against the poppet. When the inlet pressure exceeds the cracking pressure, the poppet will open to allow flow through and will reseal when the overpressure condition is below the cracking set point.

MAINTENANCE & REPAIR

This valve requires little or no maintenance. It is designed so that the cracking pressure can't be disturbed while in use. To change the cracking pressure setting requires complete removal of the valve from its pressure port. Caution: Make sure the pressure source is shut off to avoid injury, while removing the valve. The only item that will require replacement is the elastomeric seal when leakage is observed. Usually the body or spring rarely requires replacement unless there is severe corrosion. If corrosion is present typically the entire valve must be replaced and upgraded to materials which can hold up to the corrosive elements. Ordinarily the spring is supplied in stainless steel, but other options are available such as Hastelloy and titanium. The only other reason for removing the valve from the line is to adjust the cracking pressure. Under no circumstances over tighten the spring to where it bottoms out! The poppet must be allowed to travel for flow to take place.

SPECIFICATION	
1	POPPET
2	SEAL**
3	BODY
4	SPRING
5	GUIDE
6	NUT

*ALTERNATE MATERIALS: PVC
MONEL, TITANIUM, HASTELLOY
** ALTERNATE ELASTOMERS: EPDM,
TFE, KALREZ, PARFLUOR

FOR AIR OR LIQUID SERVICE
PRESSURES QUOTED ON APPLICATION

PH 973-340-9955
FX 973-340-9933
21 COLUMBUS AVE
GARFIELD, N.J. 07026

SCALE	TITLE	
NONE	RELIEF/CHECK VALVE 1/8" - 3" NPT	
DATE	DWG NO	REV
11-20-14	CKV-05NPT	D
DRAWN LP		